



Standard Test Method for Visual Examination of Used Electrical Insulating Oils of Petroleum Origin in the Field¹

This standard is issued under the fixed designation D 1524; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method for visual examination is applicable to mineral oils of petroleum origin that have been used in transformers, oil circuit breakers, or other electrical apparatus as insulating or cooling media, or both.

1.2 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

D 1500 Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)²

3. Summary of Test Method

3.1 The color of the test specimen is estimated by visually comparing the color of a specified thickness of the sample with a series of artificial standard color disk filters in a specified comparator.

3.2 The condition of the test specimen is estimated by observation of cloudiness, foreign particles, or suspended matter in the sample by reflected light.

4. Significance and Use

4.1 By use of this test method the color and condition of a test specimen of oil may be estimated during a field inspection, thus assisting in the decision as to whether or not the sample should be sent to a central laboratory for full evaluation. Cloudiness, particles of insulation, products of metal corrosion, or other undesirable suspended materials, as well as any unusual change in color may be detected. For precise determination of color in the laboratory, Test Method D 1500 should be used.

5. Apparatus

5.1 *Color Comparator*³—A color comparator suitable for estimating the color of petroleum products on the ASTM Color Scale, and for the examination of the test specimen by reflected light (Tyndall beam effect).

5.2 *Light*—A light source such as a pen light with a No. 222 bulb.

5.3 *Cloth*—Photographer's focusing cloth.

6. Preparation of Apparatus

6.1 Open the front cover of the comparator housing, and place the center of the color disk on the ring with the number plates facing the operator. Close the cover. As the disk is rotated, the number plates representing ASTM Color Numbers can be read through the upper opening on the right-hand side of the front cover. The alignment is such that only one figure is visible when a glass color standard is completely in the field of view.

6.2 The observation fields for colorimetric comparison can be seen through the two central openings. Through the prism attachment, they are seen as half-fields. The right-hand field is produced by the test specimen in a tube which is placed in the opening at the right of the instrument, while the left-hand field is formed by one of the glass color standards.

7. Procedure

7.1 *Color Determinations*—Fill a tube with the test specimen to a height convenient for full exposure in the observation field and place it in the right-hand opening of the apparatus. Quickly make the color comparison by revolving the color disk so that one standard after another is brought into the observation field. When using the comparator with the prism attachment, view the color fields with the eye in line with the center of the fields. The half-fields should be free of shadow effect which can be caused by off-center or oblique observation. For

¹ This test method is under the jurisdiction of ASTM Committee D-27 on Electrical Insulating Liquids and Gases and is the direct responsibility of Subcommittee of D27.07 on Physical Tests.

Current edition approved July 15, 1994. Published September 1994. Originally published as D1524 – 68. Last previous edition D1524 – 84 (1990).

² *Annual Book of ASTM Standards*, Vol 05.01.

³ The Hellige Oil Comparator, catalog No. 605-HT, with catalog No. 620C-55 color disk, available from Orbco Hellige, 185 T Marine St., Farmingdale, NY 11735, has been found to be suitable. This equipment may be modified to accommodate a Tyndall Beam Accessory. A prism magnifier attachment, Catalog No. 600-PA, is also available if desired. A Hellige Comparator, catalog No. 607-OC, has also been found suitable but is less convenient for field use.