This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

Designation: D1688 – 17

Standard Test Methods for Copper in Water[1]

This standard is issued under the fixed designation D1688; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope*

1.1 These test methods cover the determination of copper in water by atomic absorption spectrophotometry. Section 34 on Quality Control pertains to these test methods. Three test methods are included as follows:

Test Method	Concentration Range	Sections
A—Atomic Absorption, Direct	0.05 to 5 mg/L	7 – 15
B—Atomic Absorption, Chelation-Extraction	50 to 500 µg/L	16 – 24
C—Atomic Absorption, Graphite Furnace	5 to 100 µg/L	25 – 33

1.2 Either dissolved or total recoverable copper may be determined. Determination of dissolved copper requires filtration through a 0.45-µm (11.10) membrane filter at the time of collection. In-line membrane filtration is preferable.

1.3 The values stated in SI units are to be regarded as standard. The values given in parentheses are mathematical conversion to inch-pound units that are provided for information only and are not considered standard.

1.4 Three former photometric test methods were discontinued. Refer to Appendix X1 for historical information.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.* For specific hazard statements, see 11.3, 11.9.1, 20.10, and 22.11.

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*[2]

D858 Test Methods for Manganese in Water
D1066 Practice for Sampling Steam
D1068 Test Methods for Iron in Water
D1129 Terminology Relating to Water
D1193 Specification for Reagent Water
D1687 Test Methods for Chromium in Water
D1691 Test Methods for Zinc in Water
D1886 Test Methods for Nickel in Water
D1976 Test Method for Elements in Water by Inductively-Coupled Argon Plasma Atomic Emission Spectroscopy
D2777 Practice for Determination of Precision and Bias of Applicable Test Methods of Committee D19 on Water
D3370 Practices for Sampling Water from Closed Conduits
D3557 Test Methods for Cadmium in Water
D3558 Test Methods for Cobalt in Water
D3559 Test Methods for Lead in Water
D3919 Practice for Measuring Trace Elements in Water by Graphite Furnace Atomic Absorption Spectrophotometry
D4841 Practice for Estimation of Holding Time for Water Samples Containing Organic and Inorganic Constituents
D5673 Test Method for Elements in Water by Inductively Coupled Plasma—Mass Spectrometry
D5810 Guide for Spiking into Aqueous Samples
D5847 Practice for Writing Quality Control Specifications for Standard Test Methods for Water Analysis

3. Terminology

3.1 *Definitions:*

3.1.1 For definitions of terms used in this standard, refer to Terminology D1129.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *continuing calibration blank, n*—a solution containing no analytes (of interest) which is used to verify blank response and freedom from carryover.

[1] These test methods are under the jurisdiction of ASTM Committee D19 on Water and are the direct responsibility of Subcommittee D19.05 on Inorganic Constituents in Water.

Current edition approved June 1, 2017. Published July 2017. Originally approved in 1959. Last previous edition approved in 2012 as D1688 – 12. DOI: 10.1520/D1688-17.

[2] For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

***A Summary of Changes section appears at the end of this standard**

Copyright © ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959. United States