



Standard Practice for Coagulation-Flocculation Jar Test of Water¹

This standard is issued under the fixed designation D2035; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers a general procedure for the evaluation of a treatment to reduce dissolved, suspended, colloidal, and nonsettleable matter from water by chemical coagulation-flocculation, followed by gravity settling. The procedure may be used to evaluate color, turbidity, and hardness reduction.

1.2 The practice provides a systematic evaluation of the variables normally encountered in the coagulation-flocculation process.

1.3 The values stated in SI units are to be regarded as standard.

1.4 *This standard does not purport to address the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

D1129 Terminology Relating to Water

D1193 Specification for Reagent Water

D1293 Test Methods for pH of Water

D3370 Practices for Sampling Water from Closed Conduits

D6855 Test Method for Determination of Turbidity Below 5 NTU in Static Mode

D7315 Test Method for Determination of Turbidity Above 1 Turbidity Unit (TU) in Static Mode

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice, refer to Terminology D1129.

¹ This practice is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.03 on Sampling Water and Water-Formed Deposits, Analysis of Water for Power Generation and Process Use, On-Line Water Analysis, and Surveillance of Water.

Current edition approved Jan. 1, 2013. Published February 2013. Originally approved in 1964. Last previous edition approved in 2008 as D2035–08. DOI: 10.1520/D2035-13.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

4. Summary of Practice

4.1 The coagulation-flocculation test is carried out to determine the chemicals, dosages, and conditions required to achieve optimum results. The primary variables to be investigated using the recommended practice include, but are not limited to:

4.1.1 Chemical additives,

4.1.2 pH,

4.1.3 Temperature, and

4.1.4 Order of addition and mixing conditions.

5. Significance and Use

5.1 This practice permits the evaluation of various coagulants and coagulant aids used in the treatment of water and waste water for the same water and the same experimental conditions.

5.2 The effects of concentration of the coagulants and coagulant aids and their order of addition can also be evaluated by this practice.

6. Interferences

6.1 There are some possible interferences that may make the determination of optimum jar test conditions difficult. These include the following:

6.1.1 *Temperature Change (During Test)*—Thermal or convection currents may occur, interfering with the settling of coagulated particles. This can be prevented by temperature control.

6.1.2 *Gas Release (During Test)*—Flotation of coagulated floc may occur due to gas bubble formation caused by mechanical agitator, temperature increase or chemical reaction.

6.1.3 *Testing-Period*—Biological activity or other factors may alter the coagulation characteristics of water upon prolonged standing. For this reason the period between sampling and testing should be kept to a minimum, with the time being recorded.

7. Apparatus

7.1 *Multiple Stirrer*—A multiposition stirrer with continuous speed variation from about 20 to 150 rpm should be used. The stirring paddles should be of light gage corrosion-resistant material all of the same configuration and size. An illuminated base is useful to observe the floc formation. Precautionary