



Designation: D 3018 – 003

Standard Specification for Class A Asphalt Shingles Surfaced with Mineral Granules¹

This standard is issued under the fixed designation D 3018; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This specification covers granule-surfaced asphalt roofing shingles that meet the conditions for Class A fire test, behavior on heating, and wind testing of Type I shingles.

1.2 Shingles meeting this specification are intended to be applied with a headlap of not less than 51 mm (2 in.).

1.3 The values stated in ~~acceptable metric~~ SI units are to be regarded as the standard. The values given in parentheses are provided for information purposes only.

2. Referenced Documents

2.1 *ASTM Standards:*

¹ This specification is under the jurisdiction of ASTM Committee D08 on ~~Roofing, Waterproofing, Roofing and Bituminous Materials~~ Waterproofing and is the direct responsibility of Subcommittee D08.02 on Prepared Roofings, Shingles, and Siding Materials.

Current edition approved ~~Nov. Jan. 10, 2000~~ 3. Feb. 2003. Published ~~January 2001~~ February 2003. Originally published as D 3018 – 72, approved in 1972. Last previous edition D 3018 – 90 (1994)^{ε1}, approved in 2000 as D 3018 – 00.