



Standard Specification for Polyethylene (PE) Plastic Pipe (DR-PR) Based on Controlled Outside Diameter¹

This standard is issued under the fixed designation D3035; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope*

1.1 This specification covers polyethylene (PE) pipe made in thermoplastic pipe dimension ratios based on outside diameter IPS $\frac{1}{2}$ to 3, for both non-pressure and pressure rated water (see [Appendix X1](#)). Included are requirements for polyethylene compounds and PE plastic pipe, a system of nomenclature for PE plastic pipe, and requirements and test methods for materials, workmanship, dimensions, sustained pressure, and burst pressure. Methods of marking are also given.

NOTE 1—Significant changes have been made to this specification to remedy duplication of sizes with other specifications, for DIPS sizes and larger sizes refer to the appropriate standard specification such as Specification [F714](#) or AWWA C906.

1.2 For pipes produced under this specification that are intended for use in the distribution and transmission of potable water without oxidizing disinfectants, potable and non-potable water, grey water, reclaimed water, wastewater, force main and gravity municipal sewage, etc, the user should consult the manufacturer to determine whether the fluid being transported is compatible with polyethylene pipe and will not affect the service life beyond limits acceptable to the user.

1.3 For pipes produced under this specification that are intended for use in the distribution and transmission of potable water or other fluids containing oxidizing disinfectants (for example, Hypochlorous acid or chloramines), special requirements for PE compounds are specified in [5.2](#) and [5.3](#), and DR limitations are specified in [6.2.1.1](#) and [6.2.2.1](#).

NOTE 2—Refer to specification AWWA C901 for other suitable potable water options.

1.4 The values stated in inch-pound units are to be regarded as standard. The values given in parentheses are mathematical conversions to SI units that are provided for information only and are not considered standard.

¹ This specification is under the jurisdiction of ASTM Committee [F17](#) on Plastic Piping Systems and is the direct responsibility of Subcommittee [F17.26](#) on Olefin Based Pipe.

Current edition approved Aug. 1, 2021. Published August 2021. Originally approved in 1972. Last previous edition approved in 2015 as D3035 – 15. DOI: 10.1520/D3035-21.

1.5 The following safety hazards caveat pertains only to the test methods portion, Section [7](#), of this specification: *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

- [D618 Practice for Conditioning Plastics for Testing](#)
- [D1238 Test Method for Melt Flow Rates of Thermoplastics by Extrusion Plastometer](#)
- [D1598 Test Method for Time-to-Failure of Plastic Pipe Under Constant Internal Pressure](#)
- [D1599 Test Method for Resistance to Short-Time Hydraulic Pressure of Plastic Pipe, Tubing, and Fittings](#)
- [D1600 Terminology for Abbreviated Terms Relating to Plastics](#)
- [D2122 Test Method for Determining Dimensions of Thermoplastic Pipe and Fittings](#)
- [D2290 Test Method for Apparent Hoop Tensile Strength of Plastic or Reinforced Plastic Pipe](#)
- [D2837 Test Method for Obtaining Hydrostatic Design Basis for Thermoplastic Pipe Materials or Pressure Design Basis for Thermoplastic Pipe Products](#)
- [D3350 Specification for Polyethylene Plastics Pipe and Fittings Materials](#)
- [F412 Terminology Relating to Plastic Piping Systems](#)

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.