



Designation: D3242 – 23



Designation: 354/09

Standard Test Method for Acidity in Aviation Turbine Fuel^{1,2}

This standard is issued under the fixed designation D3242; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope*

1.1 This test method covers the determination of the acidity in aviation turbine fuel in the range from 0.000 mg/g to 0.100 mg/g KOH.

1.2 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*³

[D664 Test Method for Acid Number of Petroleum Products by Potentiometric Titration](#)

[D1193 Specification for Reagent Water](#)

[D4175 Terminology Relating to Petroleum Products, Liquid Fuels, and Lubricants](#)

¹ This test method is under the jurisdiction of ASTM International Committee D02 on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of ASTM Subcommittee D02.06 on Analysis of Liquid Fuels and Lubricants. The technically equivalent standard as referenced is under the jurisdiction of the Energy Institute Subcommittee SC-B-11.

Current edition approved Nov. 1, 2023. Published November 2023. Originally approved in 1973. Last previous edition approved in 2017 as D3242 – 11 (2017). DOI: 10.1520/D3242-23.

² This test method has been developed through the cooperative effort between ASTM and the Energy Institute, London. ASTM and IP standards were approved by ASTM and EI technical committees as being technically equivalent but that does not imply both standards are identical.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

3. Terminology

3.1 *Definitions:*

3.1.1 For definitions of terms used in this test method, refer to Terminology [D4175](#).

3.1.2 *acid number, n*—the quantity of a specified base, expressed in milligrams of potassium hydroxide per gram of sample, required to titrate a sample in a specified solvent to a specified endpoint using a specified detection system.

3.1.2.1 *Discussion*—in this test method, the solvent is a toluene-water-isopropanol mixture and the end point is determined when a green/green brown color is obtained using the specified *p*-naphtholbenzein indicator solution.

4. Summary of Test Method

4.1 The sample is dissolved in a mixture of toluene and isopropyl alcohol containing a small amount of water. The resulting single phase solution is blanketed by a stream of nitrogen bubbling through it and is titrated with standard alcoholic potassium hydroxide to the end point indicated by the color change (orange in acid and green in base) of the added *p*-naphtholbenzein solution.

5. Significance and Use

5.1 Some acids can be present in aviation turbine fuels due either to the acid treatment during the refining process or to naturally occurring organic acids. Significant acid contamination is not likely to be present because of the many check tests made during the various stages of refining. However, trace amounts of acid can be present and are undesirable because of the consequent tendencies of the fuel to corrode metals that it contacts or to impair the water separation characteristics of the aviation turbine fuel.

5.2 This test method is designed to measure the levels of acidity that can be present in aviation turbine fuel and is not suitable for determining significant acid contamination.

6. Apparatus

6.1 *Buret*—A 25 mL buret graduated in 0.1 mL subdivisions, or a 10 mL buret graduated in 0.05 mL subdivisions.

*A Summary of Changes section appears at the end of this standard