



Designation: D3487 – 24

Standard Specification for Mineral Insulating Liquid Used in Electrical Apparatus¹

This standard is issued under the fixed designation D3487; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope

1.1 This specification covers unused mineral insulating oil of petroleum origin for use as an insulating and cooling medium in new and existing power and distribution electrical apparatus, such as transformers, regulators, reactors, circuit breakers, switchgear, and attendant equipment.

1.2 This specification is intended to define a mineral insulating oil that is functionally interchangeable and miscible with existing oils, is compatible with existing apparatus and with appropriate field maintenance,² and will satisfactorily maintain its functional characteristics in its application in electrical equipment. This specification applies only to unused insulating oil as received prior to any processing.

1.3 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.4 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:³

- D92 Test Method for Flash and Fire Points by Cleveland Open Cup Tester
- D97 Test Method for Pour Point of Petroleum Products

¹ This specification is under the jurisdiction of ASTM Committee D27 on Electrical Insulating Liquids and Gases and is the direct responsibility of Subcommittee D27.01 on Mineral.

Current edition approved June 1, 2024. Published June 2024. Originally approved in 1976. Last previous edition approved in 2016 as D3487 – 16 ϵ 1. DOI:10.1520/D3487-24.

² Refer to the Institute of Electrical and Electronic Engineers, Inc. (IEEE) C 57.106, Guide for Acceptance and Maintenance of Insulating Oil in Equipment. Available from IEEE Operations Center, 445 Hoes Lane, Piscataway, NJ 08854-4141, USA.

³ For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at www.astm.org/contact. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

- D117 Guide for Sampling, Test Methods, and Specifications for Electrical Insulating Liquids
- D445 Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and Calculation of Dynamic Viscosity)
- D611 Test Methods for Aniline Point and Mixed Aniline Point of Petroleum Products and Hydrocarbon Solvents
- D664 Test Method for Acid Number of Petroleum Products by Potentiometric Titration
- D923 Practices for Sampling Electrical Insulating Liquids
- D924 Test Method for Dissipation Factor (or Power Factor) and Relative Permittivity (Dielectric Constant) of Electrical Insulating Liquids
- D971 Test Method for Interfacial Tension of Insulating Liquids Against Water by the Ring Method
- D974 Test Method for Acid and Base Number by Color-Indicator Titration
- D1275 Test Method for Corrosive Sulfur in Electrical Insulating Liquids
- D1298 Test Method for Density, Relative Density, or API Gravity of Crude Petroleum and Liquid Petroleum Products by Hydrometer Method
- D1500 Test Method for ASTM Color of Petroleum Products (ASTM Color Scale)
- D1524 Test Method for Visual Examination of Used Electrical Insulating Liquids in the Field
- D1533 Test Method for Water in Insulating Liquids by Coulometric Karl Fischer Titration
- D1816 Test Method for Dielectric Breakdown Voltage of Insulating Liquids Using VDE Electrodes
- D1903 Practice for Determining the Coefficient of Thermal Expansion of Electrical Insulating Liquids of Petroleum Origin, and Askarels
- D2112 Test Method for Oxidation Stability of Inhibited Mineral Insulating Oil by Pressure Vessel
- D2300 Test Method for Gassing of Electrical Insulating Liquids Under Electrical Stress and Ionization (Modified Pirelli Method)
- D2440 Test Method for Oxidation Stability of Mineral Insulating Oil
- D2668 Test Method for 2,6-*di-tert*-Butyl- *p*-Cresol and 2,6-*di-tert*-Butyl Phenol in Electrical Insulating Oil by Infra-red Absorption