



Designation: D 4799 – 003

Standard Test Method Practice for Accelerated Weathering Test Conditions and Procedures for Bituminous Materials (Fluorescent UV, Water Spray, and Condensation Method)¹

This standard is issued under the fixed designation D 4799; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This ~~test method~~ practice describes test conditions and procedures for fluorescent UV and condensation exposures conducted according to Practices G 151 and G 154 for bituminous roofing and waterproofing materials that have a minimum softening point of approximately 95°C (200°F) as determined by Test Method D 36. (Also see Terminology G 113.)

1.2 The values stated in SI units are to be regarded as the standard. The values given in parentheses are for information only.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*

¹ This ~~test method~~ practice is under the jurisdiction of ASTM Committee ~~D-8 D08~~ on ~~Roofing, Waterproofing, Roofing and Bituminous Materials~~ Waterproofing and is the direct responsibility of Subcommittee D08.02 on Prepared Roofings, Shingles, and Siding Materials.

Current edition approved Jan. 10, 2000³. Published ~~March 2000~~ February 2003. Originally published as ~~D 4799 – 88~~ approved in 1988. Last previous edition approved in 2000 as D 4799 – 98⁰⁰.