



Designation: D 6005 – 9603

Standard Test Method for Determining Slump Resistance of Carpet Adhesives¹

This standard is issued under the fixed designation D 6005; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method describes a procedure to measure slump, or sag, resistance of a trowel-grade carpet adhesive using a button slump test apparatus.

1.2 This test method provides a visual evaluation to relate troweled bead profile and trowel pickup.

1.3 The values stated in inch-pound units are to be regarded as the standard. The values given in parentheses are for information only.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

¹ This test method is under the jurisdiction of ASTM Committee D-14 on Adhesives and is the direct responsibility of Subcommittee D14.70 on Construction Adhesives. Current edition approved ~~Sept. 10, 1996~~ Dec. 1, 2003. Published ~~November~~ December 2003. Originally approved in 1996. Last previous edition approved in 1996 as D 6005 – 96.