This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.

Designation: D6224 – 22

Standard Practice for In-Service Monitoring of Lubricating Oil for Auxiliary Power Plant Equipment[1]

This standard is issued under the fixed designation D6224; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

A more systematic approach to monitoring auxiliary power plant equipment can help to minimize the high cost of oil changes and unplanned shutdowns. These avoided costs must be balanced against the cost of sampling and laboratory testing.

This practice is designed to help the user evaluate the condition of the lubricant through its life cycle by carrying out a meaningful program of sampling and testing of oils in use. This practice is performed in order to collect data and monitor trends which suggest any signs of lubricant deterioration and to ensure a safe, reliable, and cost-effective operation of the monitored plant equipment.

1. Scope*

1.1 This practice covers the requirements for the effective monitoring of mineral oil and phosphate ester fluid lubricating oils in service auxiliary (non-turbine) equipment used for power generation. Auxiliary equipment covered includes gears, hydraulic systems, diesel engines, pumps, compressors, and electrohydraulic control (EHC) systems. It includes sampling and testing schedules and recommended action steps, as well as information on how oils degrade.

NOTE 1—Other types of synthetic lubricants are sometimes used but are not addressed in this practice because they represent only a small fraction of the fluids in use. Users of these fluids should consult the manufacturer to determine recommended monitoring practices.

1.2 This practice does not cover the monitoring of lubricating oil for steam and gas turbines. Rather, it is intended to complement Practice D4378.

1.3 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.5 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards:*[2]

D92 Test Method for Flash and Fire Points by Cleveland Open Cup Tester

D95 Test Method for Water in Petroleum Products and Bituminous Materials by Distillation

D257 Test Methods for DC Resistance or Conductance of Insulating Materials

D445 Test Method for Kinematic Viscosity of Transparent and Opaque Liquids (and Calculation of Dynamic Viscosity)

D664 Test Method for Acid Number of Petroleum Products by Potentiometric Titration

D665 Test Method for Rust-Preventing Characteristics of Inhibited Mineral Oil in the Presence of Water

D892 Test Method for Foaming Characteristics of Lubricating Oils

D893 Test Method for Insolubles in Used Lubricating Oils

D943 Test Method for Oxidation Characteristics of Inhibited Mineral Oils

D974 Test Method for Acid and Base Number by Color-Indicator Titration

[1] This practice is under the jurisdiction of ASTM Committee D02 on Petroleum Products, Liquid Fuels, and Lubricantsand is the direct responsibility of Subcommittee D02.C0.01 on Turbine Oil Monitoring, Problems and Systems.

Current edition approved April 1, 2022. Published April 2022. Originally approved in 1998. Last previous edition approved in 2016 as D6224 – 16. DOI: 10.1520/D6224-22.

[2] For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

*A Summary of Changes section appears at the end of this standard

Copyright © ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959. United States