



Designation: D7284 – 13 (Reapproved 2017)

Standard Test Method for Total Cyanide in Water by Micro Distillation followed by Flow Injection Analysis with Gas Diffusion Separation and Amperometric Detection¹

This standard is issued under the fixed designation D7284; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method is used to determine the concentration of total cyanide in an aqueous wastewater or effluent. This test method detects the cyanides that are free (HCN and CN^-) and strong-metal-cyanide complexes that dissociate and release free cyanide when refluxed under strongly acidic conditions.

1.2 This test method may not be applicable to process solutions from precious metals mining operations.

1.3 This procedure is applicable over a range of approximately 2 to 500 $\mu\text{g/L}$ (parts per billion) total cyanide. Higher concentrations can be measured with sample dilution or lower injection volume.

1.4 The determinative step of this test method utilizes flow injection with amperometric detection based on Test Method D6888. Prior to analysis, samples must be distilled with a micro-distillation apparatus described in this test method or with a suitable cyanide distillation apparatus specified in Test Methods D2036.

1.5 The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.* Specific hazard statements are given in 8.6 and Section 9.

1.7 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This test method is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.06 on Methods for Analysis for Organic Substances in Water.

Current edition approved July 15, 2017. Published July 2017. Originally approved in 2008. Last previous edition approved in 2013 as D7284 – 13. DOI: 10.1520/D7284-13R17.

2. Referenced Documents

2.1 ASTM Standards:²

- D1129 Terminology Relating to Water
- D1193 Specification for Reagent Water
- D2036 Test Methods for Cyanides in Water
- D2777 Practice for Determination of Precision and Bias of Applicable Test Methods of Committee D19 on Water
- D3856 Guide for Management Systems in Laboratories Engaged in Analysis of Water
- D5847 Practice for Writing Quality Control Specifications for Standard Test Methods for Water Analysis
- D6696 Guide for Understanding Cyanide Species
- D6888 Test Method for Available Cyanides with Ligand Displacement and Flow Injection Analysis (FIA) Utilizing Gas Diffusion Separation and Amperometric Detection
- D7365 Practice for Sampling, Preservation and Mitigating Interferences in Water Samples for Analysis of Cyanide
- E691 Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method

3. Terminology

3.1 Definitions:

3.1.1 For definitions of terms used in this standard, refer to Terminology D1129 and Guide D6696.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *total cyanide, n*—total cyanide is an analytically defined term that refers to the sum total of all of the inorganic chemical forms of cyanide that dissociate and release free cyanide when refluxed under strongly acidic conditions.

3.2.1.1 *Discussion*—Total cyanide is determined analytically through strong acid distillation or UV radiation followed by analysis of liberated free cyanide on aqueous samples preserved with NaOH (pH~12). In water, total cyanide includes the following dissolved species: free cyanide, weak acid dissociable metal cyanide complexes and strong metal cyanide complexes. Also, some of the strong metal cyanide complexes,

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.