



Designation: D7349/D7349M – 15 (Reapproved 2024)

Standard Test Method for Determining the Capability of Roofing and Waterproofing Materials to Seal Around Fasteners¹

This standard is issued under the fixed designation D7349/D7349M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This qualitative test method determines the capability of asphalt-based roofing or waterproofing material to seal around a fastener that penetrates the material and prevent transmission of liquid water through the material at the penetration under defined conditions.

1.2 This test method is provided for adoption by ASTM or other consensus-based roofing and waterproofing product specifications as a standardized means to evaluate capability to seal around a fastener. Performance of this test method after subjecting the product to conditioning intended to simulate environmental stresses and strains is not prohibited.

1.3 The text of this test method references notes and footnotes which provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the standard.

1.4 The values stated in either SI units or inch-pound units are to be regarded separately as standard. The values stated in each system may not be exact equivalents; therefore, each system shall be used independently of the other. Combining values from the two systems may result in nonconformance with the standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This test method is under the jurisdiction of ASTM Committee D08 on Roofing and Waterproofing and is the direct responsibility of Subcommittee D08.02 on Steep Roofing Products and Assemblies.

Current edition approved Nov. 1, 2024. Published November 2024. Originally approved in 2008. Last previous edition approved in 2019 as D7349/D7349M – 15 (2019). DOI: 10.1520/D7349_D7349M-15R24.

2. Referenced Documents

2.1 ASTM Standards:²

D1079 Terminology Relating to Roofing and Waterproofing
D3462/D3462M Specification for Asphalt Shingles Made from Glass Felt and Surfaced with Mineral Granules
D5147/D5147M Test Methods for Sampling and Testing Modified Bituminous Sheet Material
F1667 Specification for Driven Fasteners: Nails, Spikes, and Staples

3. Terminology

3.1 *Definitions*—For definitions of terms used in this test method, refer to Terminology **D1079**.

4. Summary of Test Method

4.1 The capability of asphalt-based roofing or waterproofing materials to seal around a penetrating fastener and prevent the passage of liquid water at the fastener/material interface is determined by penetrating the material with a fastener, erecting a water column over that penetration, and monitoring the assembly for water passage for a period of time.

4.2 The test method includes protocols that establish levels for the test method parameters. The protocol used to evaluate a material is designated in a standard specification for the material or by the user of this test method.

5. Significance and Use

5.1 In some situations, penetration through asphalt-based roofing or waterproofing materials by fasteners is a required part of the material installation process or occurs during installation of other system components. When fasteners penetrate the material as a purposeful and planned part of the construction process, it is reasonable to expect that materials designed to limit migration of liquid water at the interface between the penetrating fastener and the material will do so. This qualitative test method provides a means to evaluate the

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at www.astm.org/contact. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.