Designation: D7418 – 12

Standard Practice for Set-Up and Operation of Fourier Transform Infrared (FT-IR) Spectrometers for In-Service Oil Condition Monitoring[1]

This standard is issued under the fixed designation D7418; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

This practice describes the instrument set-up and operation parameters for using FT-IR spectrometers for in-service oil condition monitoring. The following parameters are typically monitored for petroleum and hydrocarbon based lubricants: water, soot, oxidation, nitration, phosphate antiwear additives, fuel dilution (gasoline or diesel), sulfate by-products and ethylene glycol. Measurement and data interpretation parameters are standardized to allow operators of different FT-IR spectrometers to obtain comparable results by employing the same techniques. Two approaches may be used to monitor in-service oil samples by FT-IR spectrometry: *(1)* direct trend analysis and *(2)* differential (spectral subtraction) trend analysis. The former involves measurements made directly on in-service oil samples, whereas the latter involves measurements obtained after the spectrum of a reference oil has been subtracted from the spectrum of the in-service oil being analyzed. Both of these approaches are described in this practice, and it is up to the user to determine which approach is more appropriate.

1. Scope

1.1 This practice covers the instrument set-up and operation parameters for using FT-IR spectrometers for in-service oil condition monitoring for both direct trend analysis and differential trend analysis approaches.

1.2 This practice describes how to acquire the FT-IR spectrum of an in-service oil sample using a standard transmission cell and establishes maximum allowable spectral noise levels.

1.3 Measurement and integrated parameters for individual in-service oil condition monitoring components and parameters are not described in this practice and are described in their respective test methods.

1.4 The values stated in SI units are to be regarded as the standard. The values given in parentheses are for information only.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 *ASTM Standards:*[2]

D4057 Practice for Manual Sampling of Petroleum and Petroleum Products

E131 Terminology Relating to Molecular Spectroscopy

E168 Practices for General Techniques of Infrared Quantitative Analysis (Withdrawn 2015)[3]

E1421 Practice for Describing and Measuring Performance of Fourier Transform Mid-Infrared (FT-MIR) Spectrometers: Level Zero and Level One Tests

E1866 Guide for Establishing Spectrophotometer Performance Tests

E2412 Practice for Condition Monitoring of In-Service Lubricants by Trend Analysis Using Fourier Transform Infrared (FT-IR) Spectrometry

3. Terminology

3.1 *Definitions:*

3.1.1 For definitions of terms relating to infrared spectroscopy used in this practice, refer to Terminology E131.

3.1.2 *Fourier transform infrared (FT-IR) spectrometry, n*—form of infrared spectrometry in which an interferogram is

[1] This practice is under the jurisdiction of ASTM Committee D02 on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee D02.96 on In-Service Lubricant Testing and Condition Monitoring Services.

Current edition approved Dec. 1, 2012. Published December 2012. Originally approved in 2007. last previous edition approved in 2007 as D7418 – 07. DOI: 10.1520/D7418-12.

[2] For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

[3] The last approved version of this historical standard is referenced on www.astm.org.

Copyright © ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959. United States