



Designation: D7528 – 21

Standard Test Method for Bench Oxidation of Engine Oils by ROBO Apparatus¹

This standard is issued under the fixed designation D7528; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

INTRODUCTION

This test method is written for use by laboratories that make use of ASTM Test Monitoring Center (TMC)² services (see [Annex A1](#) – [Annex A4](#)).

The TMC provides reference oils, and engineering and statistical services to laboratories that desire to produce test results that are statistically similar to those produced by laboratories previously calibrated by the TMC.

In general, the Test Purchaser decides if a calibrated test stand is to be used. Organizations such as the American Chemistry Council require that a laboratory utilize the TMC services as part of their test registration process. In addition, the American Petroleum Institute and the Gear Lubricant Review Committee of the Lubricant Review Institute (SAE International) require that a laboratory use the TMC services in seeking qualification of oils against their specifications.

The advantage of using the TMC services to calibrate test stands is that the test laboratory (and hence the Test Purchaser) has an assurance that the test stand was operating at the proper level of test severity. It should also be borne in mind that results obtained in a non-calibrated test stand may not be the same as those obtained in a test stand participating in the ASTM TMC services process.

1. Scope*

1.1 This test method describes a bench procedure to simulate the oil aging encountered in Test Method [D7320](#), the Sequence IIIG engine test method. These aged oils are then tested for kinematic viscosity and for low-temperature pumpability properties as described in the Sequence IIIGA engine test, Appendix X1 of Test Method [D7320](#).

1.2 *Units*—The values stated in SI units are to be regarded as standard. No other units of measurement are included in this standard.

1.2.1 *Exceptions*—There are no SI equivalents for some apparatus in [Section 6](#), and there are some figures where inch units are to be regarded as standard.

¹ This test method is under the jurisdiction of ASTM Committee [D02](#) on Petroleum Products, Liquid Fuels, and Lubricants and is the direct responsibility of Subcommittee [D02.B0.07](#) on Development and Surveillance of Bench Tests Methods.

Current edition approved Jan. 1, 2021. Published January 2021. Originally approved in 2009. Last previous edition approved in 2017 as D7528 – 17a. DOI: 10.1520/D7528-21.

² Until the next revision of this test method, the ASTM Test Monitoring Center will update changes in the test method by means of information letters. Information letters may be obtained from the ASTM Test Monitoring Center, 6555 Penn Ave., Pittsburgh, PA 15206-4489. Attention: Administrator. This edition incorporates revisions in all information letters through No. 20-1.

1.3 This test method is arranged as follows:

	Section
Scope	1
Reference Documents	2
Terminology	3
Summary of Test Method	4
Significance and Use	5
Apparatus	6
Reagents and Materials	7
Hazards	8
New and Existing Test Stand Calibration	9
Procedure	10
Cleaning	11
Calculations and Determination of Test Results	12
Report	13
Precision and Bias	14
Keywords	15
Annexes	
ASTM Test Monitoring Center: Organization	Annex A1
ASTM Test Monitoring Center: Calibration Procedures	Annex A2
ASTM Test Monitoring Center: Maintenance Activities	Annex A3
ASTM Test Monitoring Center: Related Information	Annex A4
Reaction Vessel	Annex A5
Reaction Vessel Head	Annex A6
Reaction Vessel-to-Head Seal	Annex A7
Agitator Turbine Blade	Annex A8
Agitator Packing Gland	Annex A9
Nitrogen Dioxide Graduated Tube	Annex A10
Vacuum System Plumbing	Annex A11
Vacuum Trap Condensers	Annex A12
Setting the Vacuum Control Valve	Annex A13
Appendixes	

*A Summary of Changes section appears at the end of this standard