



Standard Practice for Conducting an Interlaboratory Study to Determine the Precision of a Test Method¹

This standard is issued under the fixed designation E691; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the U.S. Department of Defense.

1. Scope

1.1 This practice describes the techniques for planning, conducting, analyzing, and treating the results of an interlaboratory study (ILS) of a test method. The statistical techniques described in this practice provide adequate information for formulating the precision statement of a test method.

1.2 This practice does not concern itself with the development of test methods but rather with gathering the information needed for a test method precision statement after the development stage has been successfully completed. The data obtained in the interlaboratory study may indicate, however, that further effort is needed to improve the test method.

1.3 Since the primary purpose of this practice is the development of the information needed for a precision statement, the experimental design in this practice may not be optimum for evaluating materials, apparatus, or individual laboratories.

1.4 *Field of Application*—This practice is concerned exclusively with test methods which yield a single numerical figure as the test result, although the single figure may be the outcome of a calculation from a set of measurements.

1.4.1 This practice does not cover methods in which the measurement is a categorization; however, for many practical purposes categorical outcomes can be scored, such as zero-one scoring for binary measurements or as integers, ranks for example, for well-ordered categories and then the test result can be defined as an average, or other summary statistic, of several individual scores.

1.5 *This standard may involve hazardous materials, operations, and equipment. This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

¹ This practice is under the jurisdiction of ASTM Committee E11 on Quality and Statistics and is the direct responsibility of Subcommittee E11.20 on Test Method Evaluation and Quality Control.

Current edition approved Sept. 1, 2019. Published October 2019. Originally approved in 1979. Last previous edition approved in 2018 as E691 – 18. DOI: 10.1520/E0691-19.

1.6 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 *ASTM Standards*:²

E29 Practice for Using Significant Digits in Test Data to Determine Conformance with Specifications

E177 Practice for Use of the Terms Precision and Bias in ASTM Test Methods

E456 Terminology Relating to Quality and Statistics

E1169 Practice for Conducting Ruggedness Tests

E1402 Guide for Sampling Design

E2282 Guide for Defining the Test Result of a Test Method

3. Terminology

3.1 *Definitions*—Terminology E456 provides a more extensive list of terms in E11 standards.

3.1.1 *accuracy, n*—the closeness of agreement between a test result and an accepted reference value. **E177**

3.1.2 *bias, n*—the difference between the expectation of the test results and an accepted reference value. **E177**

3.1.3 *interlaboratory study, (ILS) in ASTM, n*—a designed procedure for obtaining a precision statement for a test method, involving multiple laboratories, each generating replicate test results on one or more materials.

3.1.4 *observation, n*—the process of obtaining information regarding the presence or absence of an attribute of a test specimen, or of making a reading on a characteristic or dimension of a test specimen. **E2282**

3.1.5 *precision, n*—the closeness of agreements between independent test results obtained under stipulated conditions. **E177**

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.