



Designation: E 720 – 94

Standard Guide for Selection and Use of Neutron-Activation Foils for Determining Neutron Spectra Employed in Radiation- Hardness Testing of Electronics¹

This standard is issued under the fixed designation E 720; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

This standard has been approved for use by agencies of the Department of Defense.

1. Scope

1.1 This guide covers the selection and use of neutron-activation detector materials to be employed in neutron spectra adjustment techniques used for radiation-hardness testing of electronic semiconductor devices. Foils are described that have been used at many radiation hardness-testing facilities, and comments are offered in table footnotes concerning the appropriateness of each reaction as judged by its cross-section accuracy, ease of use as an activation foil, and by past successful application. This guide also discusses the fluence-uniformity, neutron self-shielding, and fluence-depression corrections that need to be considered in choosing the foil thickness, the foil covers, and the foil locations. These considerations are relevant for the determination of neutron spectra from assemblies such as TRIGA- and Godiva-type reactors and from Californium irradiators. This guide may also be applicable to other broad energy distribution sources up to 20 MeV.

NOTE 1—For definitions on terminology used in this guide, see Terminology E 170.

1.2 This guide also covers the measurement of the gamma-ray or beta-ray emission rates from the activation foils and the calculation of the absolute specific activities of these foils. The principal measurement technique is high-resolution gamma-ray spectrometry. The activities are used in the determination of the energy-fluence spectrum of the neutron source. See Guide E 721.

1.3 Details of measurement and analysis are covered as follows:

1.3.1 Corrections involved in measuring the foil activities include those for finite foil size and thickness in the calibration of the gamma-ray detector, for pulse-height analyzer deadtime and pulse-pileup losses, and for background radioactivity.

1.3.2 The primary method for detector calibration that uses secondary standard gamma-ray emitting sources is considered

in this guide and in General Methods E 181. In addition, an alternative method in which the foils are activated in the known spectrum of a benchmark neutron field is discussed in Guide E 1018.

1.3.3 A data analysis method is presented which accounts for the following: detector efficiency; background subtraction; irradiation, waiting, and counting times; fission yields and gamma-ray branching ratios; and self-absorption of gamma rays and neutrons in the foils.

1.4 The values stated in SI units are to be regarded as the standard.

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 General considerations of neutron-activation detectors discussed in Practice E 261, Test Method E 262, and Guides E 721 and E 844 are applicable to this guide. Background information for applying this guide are given in these and other relevant standards as follows:

2.2 ASTM Standards:

E 170 Terminology Relating to Radiation Measurements and Dosimetry²

E 181 Test Methods for Detector Calibration and Analysis of Radionuclides²

E 261 Practice for Determining Neutron Fluence Rate, Fluence, and Spectra by Radioactivation Techniques²

E 262 Test Method for Determining Thermal Neutron Reaction and Fluence Rates by Radioactivation Techniques²

E 263 Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Iron²

E 264 Test Method for Measuring Fast-Neutron Reaction Rates by Radioactivation of Nickel²

E 265 Test Method for Measuring Reaction Rates and Fast-Neutron Fluences by Radioactivation of Sulfur-32²

¹ This guide is under the jurisdiction of ASTM Committee E-10 on Nuclear Technology and Applications and is the direct responsibility of Subcommittee E10.07 on Radiation Effects on Electronic Materials and Devices and Pulsed Radiation Effects.

Current edition approved Sept. 15, 1994. Published November 1994. Originally published as E 720 – 80. Last previous edition E 720 – 93.

² *Annual Book of ASTM Standards*, Vol 12.02.