



Standard Practices for Sampling for Particles in Aerospace Fluids and Components¹

This standard is issued under the fixed designation F303; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 These practices cover sampling procedures for use in determining the particle cleanliness of liquids and liquid samples from components. Three practices, A, B, and C, have been developed on the basis of component geometry in order to encompass the wide variety of configurations. These practices establish guidelines to be used in preparing detailed procedures for sampling specific components.

NOTE 1—The term cleanliness used in these practices refers to solid particles in the liquid. It does not generally cover other foreign matter such as gases, liquids, and products of chemical degradation. Cleanliness with respect to particulate contamination does not necessarily give any indication of the other types of contamination.

1.2 All components, regardless of application, may be tested provided (1) the fluid medium selected is completely compatible with the materials, packing and fluid used in the test component, and test apparatus, and (2) the fluid is handled in accordance with the manufacturer's recommendations and precautions. A liquid shall be used as the test fluid medium. These test fluids may be flushing, rinsing, packing, end use operating, or suitable substitutes for end use operating fluids. (**Warning**—Practices for sampling surface cleanliness by the vacuum cleaner technique (used on clean room garments and large storage tanks) sampling gaseous fluids and handling hazardous fluids such as oxidizers, acids, propellants, and so forth, are not within the scope of the practices presented; however, they may be included in addendums or separate practices at a later date.

Substitute fluids are recommended in place of end item fluids for preassembly cleanliness determinations on components using hazardous end item fluids. After obtaining the sample, the substitute fluid must be totally removed from the test part with particular caution given to the possibility of trapped fluid. It is hazardous to use a substitute fluid for testing assembled parts where the fluid can be trapped in dead ends, behind seals, and so forth.)

NOTE 2—The word fluid used in these practices shall be assumed to be a liquid, unless otherwise stated.

1.3 The cleanliness of assemblies with or without moving parts may be determined at the time of test; however, movement of internal component parts during the test will create unknown quantities of contamination from wear. Practice B covers configurations requiring dynamic actuation to achieve a sample. The practice does not differentiate between built-in particles and wear particles.

NOTE 3—Defining allowable cleanliness limits is not within the scope of these practices.

1.4 The three practices included are as follows:

	Sections
Practice A—Static Fluid Sampling (Method for extracting fluid from the test article for analysis. This applies to components that have a cavity from which fluid may be extracted)	5 – 13
Practice B—Flowing Fluid Sampling (Method for flushing contaminants from the test article for analysis. This applies to components which fluid can pass (1) directly through, or (2) pass into and out of by cycling)	14 – 22
Practice C—Rinse Fluid Sampling (Method for rinsing contaminants from the test article's surfaces. The rinse fluid is analyzed for contamination. This applies to components that do not have a fluid cavity or for other reasons are not adaptable to Practices A and B)	23 – 31

1.5 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:²

D1836 Specification for Commercial Hexanes

F311 Practice for Processing Aerospace Liquid Samples for Particulate Contamination Analysis Using Membrane Filters

¹ These practices are under the jurisdiction of ASTM Committee E21 on Space Simulation and Applications of Space Technology and are the direct responsibility of Subcommittee E21.05 on Contamination.

Current edition approved Oct. 1, 2016. Published October 2016. Originally approved in 1965 as D2429–65 T. Redesignated F303 in 1970. Last previous edition approved in 2008 as F303 – 08. DOI: 10.1520/F0303-08R16.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.